

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod liseň 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1050998

Product: Current discharge gap

Type: MCD 125-B/NPE, MC 125-B/NPE

Rating: $U_n=230$ V/50-60 Hz, $U_c=225$ V AC, $U_p<2,5$ kV (MC125-B/NPE),
 $I_{imp}(10/350)=125$ kA, $U_c=230$ V AC, $U_p<1,3$ kV

Ordering firm: OBO Bettermann Praha s. r. o.
Modletice 81, 251 01 Říčany u Prahy, Czech Republic

Manufacturer: OBO Bettermann GmbH + Co.KG
Hütinger Ring 52, Menden D-58694, Germany

Trade mark:

The test results are stated in the test-report No.: 503272-01/01 of: 19.09.2005

A sample of the product was found to be in conformity with:
ČSN EN 61643:03

The validity of the certificate is limited to: 30.9.2008



6.10.2005

Prague

Kudrna

Pavel Kudrna
Certification and Inspection Manager

Stamp



503272-01